



# Envirochem Testing & Consultancy LLP

(Formerly known as Envirochem Testing Lab & Research Centre)

(GOVT. APPROVED LAB)

(An ISO 9001 : 2015, ISO 14001 : 2015, ISO 45001 : 2018 Certified Lab)

Plot No. 165, 1st Floor, Sector-25, Part-II, HUDA, Panipat-132103, Hr.

M. : +91 90348 91129, 89501 75388

Email : envirochemtestinglab@gmail.com

Web. : www.etlrc.com

## TEST REPORT

Report No	ETL/PNP/51840	Report Date	15.06.2024	Doc No.	ETL/QF/7.8/01
Issue to: M/s Divya Waste Management Co. VPO Shahpur Distt. Jind		Party's Ref No: Nil Work Order No: 36840 Period of Testing: 15.06.2024			

### SAMPLE PARTICULARS

1	Type of sample	: DG NOISE- (62.5 KVA)
2	Date of sample measurement	: 15.06.2024
3	Purpose of analysis	: Monitoring purpose
4	Sample collected/ supplied by	: By Lab Representative

### OBSERVATIONS


Sr. No.	Point of measurement	I	II	III	IV	V	VI
1.	Acoustic Enclosure (0.5 m away from DG)	71.4	70.4	72.3	73.2	68.4	71.4

### TEST RESULTS

Sr. No.	Point of measurement	Noise Level (dB)			Standard Limit (dB)
		Min.	Max.	Average	
1.	Acoustic Enclosure (0.5 m away from DG)	68.4	73.2	70.8	75

Remarks: Analysed Parameters meet the Standards Limits.

\*\*\*\*\*End Report\*\*\*\*\*

  
Verified By  
Chemist



Authorized By  
Neha Singh

- N 1. Samples shall be disposed off after 15 days issue of test report unless specified.  
O 2. Results listed above related to the tested samples, Endorsement of the same is neither inferred nor implemented.  
T 3. The test report shall not be reproduced full or in part & can't be used as proof in the court of law.  
E 4. The test report should not be used in any advertising agency/media without the written approval of laboratory